



PLX51-DLplus-232

Data Logger Plus
Module

July 29, 2022

Your Feedback Please

We always want you to feel that you made the right decision to use our products. If you have suggestions, comments, compliments or complaints about our products, documentation, or support, please write or call us.

ProSoft Technology, Inc.

+1 (661) 716-5100

+1 (661) 716-5101 (Fax)

www.prosoft-technology.com

support@prosoft-technology.com

PLX51-DLplus-232 Release Notes
For Public Use.

July 29, 2022

ProSoft Technology®, is a registered copyright of ProSoft Technology, Inc. All other brand or product names are or may be trademarks of, and are used to identify products and services of, their respective owners.

Content Disclaimer

This documentation is not intended as a substitute for and is not to be used for determining suitability or reliability of these products for specific user applications. It is the duty of any such user or integrator to perform the appropriate and complete risk analysis, evaluation and testing of the products with respect to the relevant specific application or use thereof. Neither ProSoft Technology nor any of its affiliates or subsidiaries shall be responsible or liable for misuse of the information contained herein. Information in this document including illustrations, specifications and dimensions may contain technical inaccuracies or typographical errors. ProSoft Technology makes no warranty or representation as to its accuracy and assumes no liability for and reserves the right to correct such inaccuracies or errors at any time without notice. If you have any suggestions for improvements or amendments or have found errors in this publication, please notify us.

No part of this document may be reproduced in any form or by any means, electronic or mechanical, including photocopying, without express written permission of ProSoft Technology. All pertinent state, regional, and local safety regulations must be observed when installing and using this product. For reasons of safety and to help ensure compliance with documented system data, only the manufacturer should perform repairs to components. When devices are used for applications with technical safety requirements, the relevant instructions must be followed. Failure to use ProSoft Technology software or approved software with our hardware products may result in injury, harm, or improper operating results. Failure to observe this information can result in injury or equipment damage.

© 2022 ProSoft Technology. All Rights Reserved.

Contents

Your Feedback Please	2
Content Disclaimer	2
 1 Start Here	 4
1.1 About the PLX51-DLplus-232	4
1.2 Release Enhancements	5
 2 Support, Service & Warranty	 7
2.1 Contacting Technical Support	7
2.2 Warranty Information	7

1 Start Here

This document highlights the new features, fixes, enhancements and known issues for the PLX51-DLplus-232 gateway.

1.1 About the PLX51-DLplus-232

Model	Standards
PLX51-DLplus-232	UL/cUL; Class1Div2

The PLX51-DLplus-232 Data Logger is an evolution from the original PLX51-DL-232 and is ideal for remote sites with limited communications that need to log data.

OEMs can log their machine's data to identify operational problems or efficiency improvements.

The PLX51-DLplus-232 can read and store data from EtherNet/IP™ PLCs, DF1 Serial PLCs and devices, or Modbus® PLCs and devices.

The PLX51-DLplus-232 has the capacity to store over 16 million records in its solid-state non-volatile memory. Each stored record includes a Date Time stamp, Tag Name, Data Type, and Value.

Additional features of the PLX51-DLplus-232 include:

- A built in webserver to trend up to five (5) user defined variables with configurable time period.
- Stored data can be downloaded to a CSV file via the webserver or manually using the PLX50 Configuration Utility.
- Automatic data retrieval - REST API support to allow other systems to collect JSON-encoded data.

1.2 Release Enhancements

Release Version	Release Date	Description
1.003.012	20-Jul-2022	<ul style="list-style-type: none"> Customers with module version number prior to 1.003.011 will be able to successfully upgrade the module firmware to version 1.003.012 or newer. Customers with module version number 1.003.012 or newer will not be able to downgrade their firmware to 1.003.011 or older.
1.003.011	24-Jan-2022	<p>New Features</p> <ul style="list-style-type: none"> Enhanced – The trend will show signed values for all data types. Enhanced – Warning message displayed on trend server if maximum number of logs is displayed. Enhanced – Trend display will show warning message if no records are found to trend. Enhanced memory usage during power down event. Added support for Logix Boolean arrays - each Boolean in the array can be logged. <p>Fixes & Changes</p> <ul style="list-style-type: none"> Updated: <ul style="list-style-type: none"> INT and SINT datatype is in signed format when extracting data from module. When logging Modbus Boolean tags, only Bit 1 is used. A group trigger tag must be part of the group as a member for the tag to be logged. Fixed – 32bit variables losing resolution when being logged. Fixed – PLX5 Booleans were not being read correctly.
1.003.008	15-Dec-2020	<p>New Features</p> <ul style="list-style-type: none"> New Feature – when using JSON, ability to extract trend data using TagID. New Feature – added support for NTP. <p>Fixes & Changes</p> <ul style="list-style-type: none"> Updated event extraction time accuracy from one minute to one second. Updated – when using JSON to extract data, ability to read across and page boundaries. Fixed – anomaly that may cause Ethernet connection to drop when using NTP.
1.003.006	16-Apr-2020	<p>New Features</p> <p>None</p>

		Fixes & Changes <ul style="list-style-type: none"> Fixed web report CSV upload when using custom dates.
1.003.005	4-Oct-2019	New Features <ul style="list-style-type: none"> Added support for JSON requests that has HTTP and JSON sections in different TCP packets. Fixes & Changes <ul style="list-style-type: none"> Updated the Delta Y logging. If set to 0 (zero), do not log.
1.003.004	5-Aug-2019	Initial Release

2 Support, Service & Warranty

2.1 Contacting Technical Support

ProSoft Technology, Inc. is committed to providing the most efficient and effective support possible. Before calling, please gather the following information to assist in expediting this process:

- 1 Product Version Number
- 2 System architecture
- 3 Network details

If the issue is hardware related, we will also need information regarding:

- 1 Module configuration and associated ladder files, if any
- 2 Module operation and any unusual behavior
- 3 Configuration/Debug status information
- 4 LED patterns
- 5 Details about the interfaced serial, Ethernet or Fieldbus devices

Note: For technical support calls within the United States, ProSoft Technology's 24/7 after-hours phone support is available for urgent plant-down issues.

North America (Corporate Location)	Europe / Middle East / Africa Regional Office
Phone: +1.661.716.5100 info@prosoft-technology.com Languages spoken: English, Spanish REGIONAL TECH SUPPORT support@prosoft-technology.com	Phone: +33.(0)5.34.36.87.20 france@prosoft-technology.com Languages spoken: French, English REGIONAL TECH SUPPORT support.emea@prosoft-technology.com
Latin America Regional Office	Asia Pacific Regional Office
Phone: +52.222.264.1814 latinam@prosoft-technology.com Languages spoken: Spanish, English REGIONAL TECH SUPPORT support.la@prosoft-technology.com	Phone: +60.3.2247.1898 asiapc@prosoft-technology.com Languages spoken: Bahasa, Chinese, English, Japanese, Korean REGIONAL TECH SUPPORT support.ap@prosoft-technology.com

For additional ProSoft Technology contacts in your area, please visit:
www.prosoft-technology.com/About-Us/Contact-Us.

2.2 Warranty Information

For complete details regarding ProSoft Technology's TERMS & CONDITIONS OF SALE, WARRANTY, SUPPORT, SERVICE AND RETURN MATERIAL AUTHORIZATION INSTRUCTIONS, please see the documents at: www.prosoft-technology.com/legal